

# PUBLIC PRIVATE SCHOOL

## STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC PRIVATE SCHOOL INSPECTION REPORT

Geocoded 25.723308/-80.426494

**PURPOSE:**  
 ROUTINE  
 CONSTRUCT.  
 COMPLAINT  
 QASURVEY  
 OTHER

REINSPECTION  
 CHANGE OF OWNER  
 CONSULTATION  
 EPIDEMIOLOGY  
 PREOPENING

**TYPE: Public School**

CENSUS	FEMALES	MALES
688	328	360



**NAME** Ethel Koger Beckham Elem.  
**ADDRESS** 4702 SW 143 Court **CITY** Miami  
**OWNER** M-DCSB **ZIP** 33175  
**PERSON IN CHARGE** Julissa Pina **PHONE** (305) 222-8161  
**E-MAIL** julissapina@dadeschools.net

**RESULTS:**

Satisfactory  
 Incomplete  
 Unsatisfactory  
**OUT OF BUSINESS**

**Correct Violations by**  
 Next Inspection  
 8:00 AM on

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
13:15	15:45	02/07/2013	67699	13-51-08228

RE-INSPECTION DATE

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance" for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**SCHOOL SANITATION**

- 1. School Site
- 2. Playground Equipment
- 3. Athletic Equipment
- BUILDINGS**
- 4. Construction
- 5. Maintenance & Repair
- 6. Lighting/Foot-Candles
- 7. Heating, Ventilation, A/C

- 8. Natural Ventilation
- 9. Mechanical Ventilation

**SANITARY FACILITIES**

- 10. Provided/Accessible
- 11. Cleanliness & Repair
- 12. Toilet Facilities
- 13. Separation of Sexes
- 14. Fixture Ratio

**WATER SUPPLY**

- 15. Handwash Facilities
- 16. Showers/Fixtures
- 17. Shower Water Temp.
- 18. Installed/Operated/Maintained
- 19. Drinking Fountains
- 20. Approved Source

**LIQUID/SOLID WASTE**

- 21. Sewage Disposal
- 22. Solid Waste
- VECTOR/VERMIN CONTROL**
- 23. Infestation/Control
- 24. Brush/Trash
- 25. Water Collection/Drainage

**SAFETY**

- 26. First Aid Kit
- FOOD**
- 27. Food Insp. Rpt.

**OTHER**

- 28.
- 29.

**COMMENTS AND INSTRUCTIONS**

Violation #2 Repair or replace a loose handrail of the climbing steps and a partially loose white plastic side protection panel of the playground climbing equipment. Also replace some warped rubber floor tiles of same playground.  
 Code Reference FAC: Playground Equipment 64E-13.004(2)(a)(c). Playgrounds shall be constructed and maintained to permit maximum utilization of sites with elimination of sanitary and health hazards including mudholes, fragments of glass, stone and similar obstructions. Fixed playground equipment shall be anchored with substantial foundations so maximum safety is obtained. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

Violation #3 Replace several warped, broken, and/or loose rubber floor tiles under the climbing equipment in the PE area.  
 Code Reference FAC: Athletic Equipment 64E-13.004(2)(b). Athletic and recreational equipment and facilities must be kept clean and in a safe condition. Fences and equipment shall have no jagged or sharp projections. Athletic and recreational equipment and facilities must be kept clean and in a safe condition.

Violation #5 Repair moisture damaged wall close to the frame of the library's southwest back door.  
 Violation #5 Repair, replace or remove damaged area rug (tripping hazard) in classroom 146. The corners of the rug are curled-up and frayed  
 Code Reference FAC: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

Violation #6 Repair or replace two (out of four) light fixtures in

\*\*Continued On Page 2\*\*

INSPECTION CONDUCTED BY: Oswaldo Samper PHONE: (305) 623-3500  
 INSPECTION COND SIGNATURE: FAX #: \_\_\_\_\_  
 COPY OF REPORT RECEIVED BY: DATE: 2/7/2013